

METHOD OF PROVIDING A CONSTANT AC VOLTAGE TO A REMOTE VARIABLE LOAD

CROSS REFERENCE TO RELATED APPLICATIONS

This application claims priority to co-pending German Patent Application No. 102 32 074.8 entitled "Verfahren zur Versorgung einer entfernt angeordneten variablen Last mit einer konstanten Wechselspannung", filed July 15, 2003.

5

FIELD OF THE INVENTION

The invention relates to a method of providing a constant AC voltage to a variable load which is arranged remote of a voltage source, a voltage drop over an electrical supply line which connects the load to the voltage source being compensated for by a compensation AC voltage which, if added to the constant AC voltage, results into
10 the output AC voltage of the voltage source and the value of which is varied depending on the absolute value of the alternating current conducted to the load.

BACKGROUND OF THE INVENTION

If an AC voltage is provided to a load which is arranged remote of a voltage source, the output AC voltage of the voltage source does not reach the load in full. Instead, a
15 considerable voltage drop over the electrical supply line, which connects the load to the voltage source is observed. The relevant contributions to the voltage drop over the electrical supply line are provided by the ohmic resistance and the inductive reactance of the supply line. In addition, there is also a capacitive reactance which, however, may be neglected in most applications. The ohmic resistance and the

inductive reactance of the supply line are not constant so that they can not be compensated for by a constant compensation AC voltage as a necessary addition to the desired constant AC voltage at the voltage source. Instead, they vary with the total value of the alternating current conducted to the load as the total value of the voltage drop caused by the ohmic resistance is $|I| \cdot R$, and the total value of the voltage drop caused by the inductive reactance is $|I| \cdot \omega L$.

Thus, it is known in a method of the type described at the beginning to measure the total value of the alternating current conducted to the load and to multiply this total value by an adjustable constant for selecting the compensation AC voltage. The adjustable constant is selected depending on the actual supply line. This selection is, for example, effected in that the constant is increased starting at zero until the desired constant AC voltage is provided to the load. This known method does, however, not take into consideration that the voltage drop over the supply line caused by its ohmic resistance and the voltage drop over the supply line caused by its inductive reactance are to be summed up in a vector addition to determine the total voltage drop over the supply line, and that this total voltage drop over the supply line is also a vector so that an ideal compensation voltage is achieved by means of a closed vector triangle which is formed by the drop in voltage over the supply line, the output voltage of the voltage source and the AC voltage at the load. In other words, a determination of the compensation AC voltage only depending on the total value of the alternating current conducted to the load is insufficient, if a phase angle ϕ between the alternating current conducted to the load and the output AC voltage of the voltage source varies, because this variation changes the direction of the vectors mentioned above and the ratio of the real component and the imaginary component of the complex AC voltage quantities.

In a further method of the type described at the beginning, in addition to the variation of the value of the compensation AC voltage depending on the total value of the alternating current conducted to the load, a compensation capacity is connected in series with the supply line connecting the load to the voltage source to compensate for the inductive reactance by means of a capacitive reactance to such an extent that the voltage drop over the electrical supply line is now only determined by its ohmic resistance which is only depending on the total value of the alternating current conducted to the load. The phase angle between the output AC voltage of the

voltage source and the alternating current conducted to the load, however, depends on the inductivity of the whole system, which may vary to a considerable extend. Thus, it is impossible, to adjust the phase angle to zero by means of a constant capacitance. On the other hand, considerable dangers are incurred by the additional
5 high capacitance in the supply line to the load.

As a further method of providing a constant AC voltage to a variable load which is arranged remote of a voltage source, a voltage drop over an electrical supply line which connects the load to the voltage source is compensated for by means of a compensation AC voltage which, if added to the constant AC voltage, results into the
10 output AC voltage of the voltage source, the AC voltage reaching the load being measured and being used as an actual value for controlling the voltage source. This method results in a constant AC voltage at the load independently of any changes in the whole system. However, problems can occur, if measuring supply lines which also run between the voltage source and the load, are affected by disturbances. The
15 function of the known method is lost, if any of the measuring supply lines breaks.

Thus it would be desirable to provide a method of providing a constant AC voltage to a variable load by which the compensation AC voltage is selected in such a way that it results in a constant AC voltage at the load over a greater range of variations of the load. At the same time, the method should be easily applied and implemented.

SUMMARY OF THE INVENTION

The present invention relates to a method of providing a desired constant AC voltage to a variable load which is arranged remote of a voltage source, comprising the steps of compensating for a voltage drop over an electrical supply line which connects the load to the voltage source by a compensation AC voltage; the compensation AC
25 voltage being added to the desired constant AC voltage to determine an output AC voltage of the voltage source; varying the compensation AC voltage depending both on an absolute value of an alternating current conducted to the load and on a phase angle ϕ between the output AC voltage of the voltage source and the alternating current.

Other features and advantages of the present invention will become apparent to one with skill in the art upon examination of the following drawings and the detailed description. It is intended that all such additional features and advantages be included herein within the scope of the present invention, as defined by the claims.

5

DESCRIPTION OF THE INVENTION

The core idea of the new method is to consider the vectorial properties of the voltage drop over the supply line by means of the phase angle ϕ . The phase angle ϕ can be quite easily determined at the voltage source. It is, for example obtainable in that a vector product of the output AC voltage and the alternating current and a scalar
10 product of the total value of the output AC voltage and the total value of the alternating current are calculated at the voltage source. This may be effected by means of a point by point multiplication of the total values of the output AC voltage and the alternating current which are present at the same point of time, on the one hand, and the effective values of the output AC voltage and the alternating current,
15 on the other hand. These two values represent the effective electric power, on the one hand, and the apparent electric power, on the other hand.

With the new method, it became apparent that it is not critical to consider every effect of the phase angle ϕ . Instead, it has been proved as sufficient that the compensation AC voltage comprises two summands which are supply linearly
20 dependent on the total value of the alternating current, and one of which is additionally supply linearly dependent on $\cos(\phi)$ and the other of which is additionally supply linearly dependent on $\sin(\phi)$. Besides the factors $|I|$ and $\cos(\phi)$ or $\sin(\phi)$, respectively, both summands comprise a constant, which is to be adapted to the actual supply line from the voltage source to the load. The constant C_R
25 associated with the factors $|I|$ and $\cos(\phi)$ is determined by the ohmic resistance of the supply line. In the new method, this constant can quite easily be obtained in that, with an ohmic load at the place of the variable load, a total value of the full output AC voltage $|U_{full}|$ provided by the voltage source, a total value of the AC voltage $|U_{load}|$ dropping over the ohmic load, and a total value of the alternating current $|I|$ which is
30 conducted at that same time are measured. By means of the ohmic load at the place of the variable load, the phase angle ϕ between the output AC voltage of the

voltage source and the alternating current conducted to the load is minimized, i.e. ϕ is close to zero. Thus, the contribution of the inductive reactance of the supply line to the voltage drop over the supply line is also close to zero. In other words, the voltage drop over the supply line is nearly only determined by the ohmic resistance. This
5 allows for determining the constant C_R from the above measured values as $(|U_{full}| - |U_{load}|)/|I|$.

The second constant C_L associated with the factors $|I|$ and $\sin(\phi)$ represents the inductive reactance ωL of the supply line. In the new method, this value can be determine in that, with a mixed ohmic and inductive load at the place of the variable
10 load, a total value of the output AC voltage $|U_{full}|$ provided by the voltage source, a total value of the AC voltage $|U_{load}|$ dropping over the ohmic load, a total value of the current $|I|$ conducted at the same time, and the phase angle ϕ are measured. The mixed ohmic and inductive load at the place of the variable load can be the variable load itself. It is important, that the mixed ohmic and inductive load results in a
15 considerable phase angle ϕ like that one which may occur in the operation of the variable load. The constant C_L can be determined from the measured values as $[|U_{full}| - |U_{load}| - C_R * |I| * \cos(\phi)]/[|I| * \sin(\phi)]$. Whereas it is assumed in determining the constant C_L that the phase angle ϕ is negligible because of the pure ohmic load at the place of the variable load, it is assumed in determining the constant C_L that a
20 phase angle between the output AC voltage of the voltage source and the AC voltage at the load is negligible or that at least any effects of a change in this phase angle are negligible at the end. The selection of the compensation AC voltage based on the above described summands including C_R and C_L is based on this assumption. However, it becomes apparent that this assumption does not result in relevant errors,
25 i.e. despite the included approximation the AC voltage obtained at the load is very constant even with strong changes of the load.

This is particularly the case, if at least the constant C_L is determined at a value of $|U_{load}|$ which is about equal to the desired constant AC voltage. I.e. at least the constant C_L , preferably both constants C_R and C_L , are determined under conditions
30 for the supply line, which are close to the working conditions for the supply line, so that they also cover the properties of the voltage source under conditions close to the working conditions for the supply line.

As, in the new method, measurements of the total value of the AC voltage $|U_{load}|$ dropping over the load are required, i.e. measurements at a place remote of the voltage source, it has been proved as advantageous that the constants C_R and C_L are at first approximated at a value of $|U_{full}|$ which is about equal to the desired
5 constant AC voltage, and that then a value of $|U_{load}|$ which is equal to the desired constant AC voltage is approached with the approximated values. Afterwards, the final values of C_R and C_L are determined.

If the voltage source is a rotating frequency converter, an exciting power of a generator is varied to achieve a variation of the compensation AC voltage. The
10 variation of the exciting power of the generator varies the compensation AC voltage for all phases of the voltage source in the same way. Thus, a compromise has to be made, If the supply line to the load has different properties for the single phases. It is an option to determine the ideal compensation AC voltages for all phases and to calculate a mean value.

15 In case of a voltage source in form of a static frequency converter or of an electronically controlled transformer it is, however, possible and also suitable to vary the compensation AC voltage separately for each phase of the AC voltage. Thus, different conditions of the supply line for each phase can be taken into consideration to their full extent.

20

SHORT DESCRIPTION OF THE DRAWINGS

In the following, the invention is further explained and described by means of an embodiment example. Here,

Fig. 1 is a single line diagram of a supply line between a voltage source and a load, and

25 **Fig. 2** is a vector addition of the voltage drops in the arrangement according to Fig. 1.

DESCRIPTION OF THE DRAWINGS

Up to now it has been described in general that the invention is related to providing an AC voltage to a remote variable load, without giving details of the AC voltage. The mentioned problems of the prior art, however, particularly occur with AC voltages of higher frequency, i.e. at frequencies clearly above 50 or 60 Hz. With supply network AC voltages of 50 or 60 Hz, the effects of a varying phase angle between the output AC voltage of the voltage source and the current conducted to the load are often only small. A technical field, however, in which highly relevant effects of the phase angle ϕ are observed, is the power supply of airplanes on the ground. Airplanes on the ground are connected to voltage sources which provide an AC voltage of 400 Hz adapted to the electric and electronic equipment of the airplanes by means of quite long supply lines. In this frequency range the mentioned effects are highly relevant. At the same time it is important for the sensitive electronic equipment on board of an airplane that the voltage supply is effected with a constant voltage of typically 115 Volt, only small deviations of ± 3 Volt at maximum being acceptable. Naturally, a restriction to even smaller deviations should be achieved. It is easily achieved by means of the new method.

Fig. 1 illustrates a load 1 which is connected to a voltage source 3 remote of the load by means of a supply line 2. A voltage U_{load} is provided to the load 1 which essentially deviates from the output voltage U_{full} of the voltage source 3 because of the conducting properties of the supply line 2. The main contributions are caused by the ohmic resistance $I \cdot R$ and the inductive reactance $I \cdot \omega L$ of the supply line 2.

In Fig. 2 all of these quantities are depicted as vectors. The vector difference between U_{full} and U_{load} comprises two components $I \cdot R$ and $I \cdot \omega L$. These two components are perpendicular to each other. Further, the orientation of the component $I \cdot R$ with regard to U_{full} is determined by the phase angle ϕ between U_{full} and the current I conducted to the load. Thus, even with constant total values of $|I \cdot R|$ and $|I \cdot \omega L|$, the total value of $|U_{load}|$ may change with the phase angle ϕ to a considerable extent. Vice versa, this means that it is not sufficient for keeping a constant value of $|U_{load}|$ to vary $|U_{full}|$ by means of an addition which is only dependent on $|I|$. Instead, the phase angle ϕ has also to be considered. Naturally, this is particularly the case with a stronger variation of the values of ϕ . This stronger variation nearly occurs, if, for example, a constant AC voltage is to be provided to

different airplanes on the ground as loads 1. Even with one and the same airplane, the phase angle ϕ may be strongly varied because of differing activations of electric and electronic equipment in the airplane, for example, upon switching on an electric air-condition.

- 5 To the end of adding a compensation AC voltage to a constant AC voltage, which is desired for being provided to the load 1, at the voltage source 3 in such a way that the actual voltage drop over the supply line 2 is exactly compensated for so that exactly the desired AC voltage reaches the load 1, the phase angle ϕ of the alternating current conducted to the load has also to be considered besides its
10 absolute value $|I|$. Further, the ohmic resistance R and the inductive reactance ωL of the supply line 2 have to be known. $|I|$ and ϕ may be determined at the voltage source 3. However, it is not trivial to obtain the values R and ωL of the supply line in a simple way. Even if these values R and ωL are known, an exact vectorial determination of the compensation voltage according to the vector diagram of Fig. 2
15 would be difficult.

- Surprisingly, however, it can be shown that a compensation AC voltage U_{comp} can be determined by means of the following rules, and that in this way the AC voltage U_{load} at the load 1 can be kept within a very small window around the predetermined desired value of the AC voltage. The compensation AC voltage U_{comp} has two
20 summands $|I| \cdot C_R \cdot \cos(\phi)$ and $|I| \cdot C_L \cdot \sin(\phi)$. The first summand corresponds to the length of the vector $I \cdot R$, i.e. the ohmic contribution to the voltage drop over the supply line 2 in the direction of the output AC voltage U_{full} of the voltage source 3. The second summand corresponds to the length of the vector $|I| \cdot \omega L$, i.e. to the inductive contribution to the voltage drop over the supply line 2 in this same direction. If C_R is R and C_L is ωL , the compensation AC voltage U_{comp} determined from these values
25 comprises an inaccuracy, because there is a phase angle θ between U_{full} and U_{load} . This phase angle θ , however, is small so that this error has no significant effect. Further, the same error also occurs in determining the constants C_R and C_L , which determination takes place in the new method prior to the determination of the
30 compensation AC voltage U_{comp} by means of the two summands indicated above.

For determining C_R , a pure ohmic load, i.e. an ohmic resistance is connected to the supply line 2 at the place of the load 1 which typically also has an ohmic resistance

part and an inductive reactance part and possibly also a capacitive reactance part. The size of the ohmic resistance is not critical. However, it should show about the same ratio with regard to the ohmic resistance R of the supply line 2 as the desired AC voltage to be provided to the load 1 to the voltage drop over the supply line 2.

- 5 Because of the pure ohmic load at the place of the load 1, the phase angle ϕ is close to zero, as the inductive reactance ωL of the supply line 2 alone is not sufficient to incur a significant phase angle ϕ between the full voltage U_{full} and the current I . Thus, the voltage drop over the supply line 2 is nearly only determined by the ohmic resistance part $I \cdot R$. Thus, by means of measuring U_{full} and U_{load} as well as I , a value
10 for the constant C_R can be determined which is close to the ohmic resistance R of the supply line 2. Concretely, the constant C_R is determined as $(|U_{full}| - |U_{load}|)/|I|$.

- As a next step, the constant C_L is determined using the already determined constant C_R and further measurement values which are obtained with a mixed ohmic and inductive load at the place of the load 1. The mixed ohmic and inductive load can be
15 the real load 1. Anyway, it is selected so that its inductive reactance part creates a significant phase angle ϕ so that $\cos(\phi)$ is, for example, in the order of 0.8. With this load, the total values of U_{full} , U_{load} , I and ϕ are now measured. Then C_L is determined as $[|U_{full}| - |U_{load}| - C_R \cdot |I| \cdot \cos(\phi)]/[|I| \cdot \sin(\phi)]$. This corresponds to the determination of ωL from the vector diagram according to Fig. 2 without considering
20 the phase angle ϕ between U_{full} and U_{load} , and under the assumption that C_R is R . With the values of C_R and C_L determined in this way, however, a compensation AC voltage is obtained by calculating the above summands which results in an AC voltage U_{load} being provided to the load 1, which is constant within narrow limits over a broad range of variations of the load 1. I.e., the assumptions and approximations
25 on which the steps of the new method are based are innocuous. In part, they are compensated for in that both in determining the constants, particularly C_L as a measure of the inductive reactance ωL , and in the later determination of the compensation voltage the phase angle ϕ between U_{full} and U_{load} is not considered. So far as the phase angle ϕ is approximately of the same size here, all resulting
30 inaccuracies are nearly compensated for to their full extent. However, even the total of these inaccuracies is only small, because the phase angle ϕ is much smaller than ϕ . With a supply line 2, the resistance properties of which do not change, the value of the voltage U_{load} can be kept constant by means of the compensation voltage consisting of the above indicated summands with a much smaller error than

acceptable in usual applications. The compensation AC voltage is calculated in an optimum way, if the constants C_R and C_L have been determined under such conditions under which U_{load} has already been about equal to the desired AC voltage at the load. This can, for example, be achieved in that at first approximated values
5 are obtained for C_R and C_L with the total value of U_{full} being set to the desired AC voltage. Then, a value is determined for U_{full} with these approximated values to re-measure at least C_L under such conditions under which U_{load} is about equal to the desired AC voltage. The new method can be implemented at comparatively little cost as, after the determination of the constants C_R and C_L , it only requires measurements
10 of U_{full} and I , because these values also allow for a determination of the phase angle ϕ by means of a point by point multiplication, on the one hand, and a multiplication of the effective values, on the other hand. The calculation of the compensation AC voltage from the two summands indicated above is obviously even more simple.

LIST OF REFERENCE NUMERALS

- 01 load
- 02 supply line
- 03 voltage source
- 04 phase angle